

मुख्य अग्निशमन अधिकारी  
**OFFICE OF THE CHIEF FIRE OFFICER**  
अण्डमान तथा निकोबार द्वीप समूह  
**Andaman and Nicobar Islands**

Clearance Number : **FS/FCC/2023/1000**

Port Blair dated **22/06/2023**

**FIRE CLEARANCE CERTIFICATE**

This is to certify that the **RGT PUBLIC VIDHYALAYA** situated at **RGT ROAD NEAR RGT TEMPLE PORT BLAIR 744101 ,R.G.T ROAD ,PORT BLAIR** bearing Survey No. **1. 2443/1, 2. 2443/2, 3. 244/3** has been inspected and there is "**NO OBJECTION**" from fire safety point of view. The First Aid Fire Fighting arrangements in the **School** are found satisfactory and reliable for a period of one (1) year from the date of issue of this FCC, subject to no change is effected in the existing fire fighting arrangements.

Note:- Conditions for the validity of Fire Clearance Certificate(FCC)

1. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
2. FCC shall stand null and void if there is any violation in existing firefighting arrangements.
3. FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in building plan.
4. All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to operate all fire safety equipments.
5. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
6. Trained firefighting staff should be available round the clock.
7. Any deviation with regard to construction etc. shall be verified by the concerned building sanctioning authority.
8. Means of escape shall be kept unobstructed/unlocked for unhindered

evacuation in case of an emergency.

9. Occupant load in class room should not be more than 4 m<sup>2</sup> per students
10. Classes from pre-primary to 1st Standard should be at ground floor only.
11. Occupant load of multipurpose hall should be limited to 1.4 sqm per student. The students from pre-primary to Class I should not be assembled in multipurpose hall at second floor.
12. No combustible material should be used for construction of school building.

Copy to:-

1. The Secretary, PBMC, P/Blair for kind information and for ensuring occupancy of the building as per approved plan.
2. The Director of Education, P/Blair for kind information please.



**Inspector Fire Brigade (Port Blair)**  
Andaman and Nicobar Islands

**To**

JOY KUMAR ROY  
RGT ROAD NEAR RGT TEMPLE PORT BLAIR 744101  
R.G.T ROAD  
PORT BLAIR  
SOUTH ANDAMAN - 744101